



ARRO Laboratory, Inc.

Est. 1965

P.O. Box 686 Caton Farm Road
Joliet, Illinois 60434

Phone: 815-727-5436
FAX 815-740-3234

Drinking Water Analysis

Batch 171023A

Customer: JIM GABL
Company: Laraway Schools 70C
Address: 275 W Laraway Rd
City/State/Zip: Joliet, IL 60436

P.O. Number:
Date Received 10/23/2017
Date Complete 11/3/2017

Sample ID 416028 Sample Description CAF SINK1 1st Sample Date 10/21/2017 7:00:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	7.89	µg/L	JS	11/01/17 8:48	200.5R4.2

Sample ID 416029 Sample Description CAF SINK1 2nd Sample Date 10/21/2017 7:00:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	4.69	µg/L	JS	11/01/17 8:48	200.5R4.2

Sample ID 416030 Sample Description CAF SINK2 1st Sample Date 10/21/2017 7:05:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.00	µg/L	JS	11/01/17 8:48	200.5R4.2

Sample ID 416031 Sample Description CAF SINK2 2nd Sample Date 10/21/2017 7:05:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.46	µg/L	JS	11/01/17 8:48	200.5R4.2

Sample ID 416032 Sample Description EAST WTR FNT1 1st Sample Date 10/21/2017 7:10:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.37	µg/L	JS	11/01/17 8:48	200.5R4.2

Sample ID 416033 Sample Description EAST WTR FNT 1 2nd Sample Date 10/21/2017 7:10:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	< 2.00	µg/L	JS	11/01/17 8:48	200.5R4.2

Batch 171023A



ARRO Laboratory, Inc.

Est. 1965

P.O. Box 686 Caton Farm Road
Joliet, Illinois 60434

Phone: 815-727-5436
FAX 815-740-3234

Sample ID 416034 Sample Description EAST WTR FNT2 1st Sample Date 10/21/2017 7:15:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	5.88	µg/L	JS	11/01/17 8:48	200.5R4.2

Sample ID 416035 Sample Description EAST WTR FNT2 2nd Sample Date 10/21/2017 7:15:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	8.06	µg/L	JS	11/01/17 8:48	200.5R4.2

Sample ID 416036 Sample Description SO CENT WTR FNT 1st Sample Date 10/21/2017 7:20:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.58	µg/L	JS	11/01/17 8:48	200.5R4.2

Sample ID 416037 Sample Description SO CENT WTR FNT 2nd Sample Date 10/21/2017 7:20:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.78	µg/L	JS	11/01/17 8:48	200.5R4.2

I CERTIFY THAT THE RESULTS RELATE ONLY TO THE SAMPLES AND I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE, COMPLETE AND ACCURATE. I ALSO CERTIFY THAT THE TEST RESULTS MEET ALL THE REQUIREMENTS OF NELAC. Illinois EPA Certification Number 100280. Refer to most current certificate for list of accredited parameters.

APPROVED BY Joan Serdar

11/3/2017

Comments: Joan Serdar, Director